

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl11@gmail.com

To,

Akal Academy
Dhotian , Tarn Taran

No.: DWTLTT/2526/00461 Dated : 12/03/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 1711 Dated: 11/03/2026


As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 11/03/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report


Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1t@gmail.com



TC-14756

TEST REPORT

Name & Address of Customer : Akai Academy Dhotian , Tarn Taran		Customer Reference No.	No : 1711 Dated : 11/03/2026
		Sample Submitted by	Sh. Gurdial Singh
		Date of Sample Receipt	11/03/2026
		Analysis Starting Date	11/03/2026
		Analysis completion Date	12/03/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC147562600000073F	Sample Type :	Water
Test Report No.:	DWTLTT/2526/00461	Date of Issue :	12/03/2026
Registration no.:	DWTLTT/REG2526/01483	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	2000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / 475 ft
Village :	Dhotian	Habitation :	Dhotian
Block:	Naushehra Punnuan	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.77@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	341@180°C	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.65@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	300	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	220	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	48.09	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	24.3	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	23.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

(Signature)

Mr.Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For,District Water Testing Laboratory
Tarn Taran

----- End of the Test Report -----